



SIJIL PERAKUAN BAHAN
CERTIFICATE OF MATERIAL APPROVAL

Jabatan Bomba dan Penyelamat Malaysia
dengan ini memperakui bahawa
Fire and Rescue Department of Malaysia
hereby certify that

VIC ENGINEERING SDN BHD (210158-P)
No.2 & 4, Jalan Jenaris 2B,
Desa Sri Jenaris,
43000 Kajang,
Selangor DE.

Bagi bahan binaan / pemasangan keselamatan kebakaran
For building material / fire safety equipment

ALAT PENGESAN HABA

Berdasarkan piawaian
As complying with

EN 50082-1:1992, EN 50081-1:1992, IEC 801-1:1984 & IEC 801-3:1984

Tempoh sah perakuan: **31/10/2014 hingga 30/10/2015**

(DATO' RUSMANI BIN MUHAMAD)
Penolong Ketua Pengarah,
Bahagian Keselamatan Kebakaran,
b.p. Ketua Pengarah
Jabatan Bomba dan Penyelamat Malaysia.

Tarikh: 2 September 2014

No. Fail: JBPM/IP/BKK:700-7/2/13-6 (10)
No.Siri: AK/H-DETECT/266/2003 (P11)

LAMPIRAN A1

Jenama	:	'YAMADO'
Model & Spesifikasi	:	RATE OF RISE HEAT DETECTOR (MODEL AHR-871)
Nama & Alamat Pengeluar	:	HORING LIH INDUSTRIAL CO LTD TAIWAN
No. Laporan ujian/Tarikh	:	TUV RHEINLAND NO. P9830026 E 01 (30/11/1998), TUV 09830026002 (02/12/2003), LPCB NO.506 (15/04/2006) & TUV 10029030-001 (13/08/2010)
Skim Persijilan Barangan	:	-----
Had Kegunaan	:	MEMATUHI UBBL 1984, SPESIFIKASI UJIAN DAN SYARAT-SYARAT TAMBAHAN SPT DI LAMPIRAN A2 & A3.



Tempoh sah perakuan: 31/10/2014 hingga 30/10/2015