

No. Fail: JBPM/IP/BKK:700-7/2/22-163 (12)
(PEMBAHARUAN: KEEMPAT)

SIJIL PEPASANGAN KESELAMATAN KEBAKARAN

APPROVAL CERTIFICATE

Jabatan Bomba dan Penyelamat Malaysia
dengan ini memperakukan
Fire and Rescue Department of Malaysia
hereby certify



CERTIFIED TO
ISO 9001 : 2008
CERT. NO: AR 5037



CERTIFIED TO
ISO 9001 : 2008
CERT. NO: AR5037

FIRE SUPPRESSION SYSTEM

Berdasarkan Piawaian
Complying with

UL 300 & UL 1254

Syarikat Berdaftar
Registered company

VIC ENGINEERING SDN BHD (210158-P)
No.2 & 4, Jalan Jenaris 2B,
Desa Sri Jenaris,
43000 Kajang,
Selangor Darul Ehsan.

Tempoh sah perakuan: **01/04/2017 hingga 31/03/2018**

(PKPJB HARON BIN HJ TAHIR)
Bahagian Keselamatan Kebakaran,
b.p. Ketua Pengarah
Jabatan Bomba dan Penyelamat Malaysia.

Tarikh: 20 Januari 2017

**** Peringatan:**
Sila patuhi sepenuhnya syarat-syarat dan had kegunaan
seperti dalam Lampiran A1

No. Fail: **JBPM/IP/BKK:700-7/2/22-163 (12)**
No.Siri: **AK/FSS/962/2013 (P4)**

LAMPIRAN A1

Jenis Alat Kelengkapan	: WET-CHEMICAL SOLUTION EXTINGUISHING SYSTEM (FOR KITCHEN HOOD)
Jenama & Spesifikasi	: ANSUL (PIRANHA R102)
Nama & Alamat Pengeluar	: ANSUL INC. (USA)
No. Laporan Ujian/Tarikh	: UL EX3470 (13/04/2012), UL GOAS.EX3470 (22/12/2014) & UL GOAS.EX3470 (Last Updated 17/06/2016)
Skim Persijilan Barangan	: -----
Had Kegunaan	: DIBENARKAN UNTUK KAWASAN 'LOCAL APPLICATION' (KITCHEN HOOD) DAN MEMATUHI SYARAT TAMBAHAN SEPERTI DI LAMPIRAN A2, A3 & A4.



Tempoh sah perakuan: **01/04/2017 hingga 31/03/2018**