

No. Fail: JBPM/IP/BKK:700-7/2/22-104 (15)
(PEMBAHARUAN: KEENAM)

SIJIL PEPASANGAN KESELAMATAN KEBAKARAN

APPROVAL CERTIFICATE

Jabatan Bomba dan Penyelamat Malaysia
dengan ini memperakukan
Fire and Rescue Department of Malaysia
hereby certify



CERTIFIED TO
ISO 9001:2008
CERT. NO: AK 0037



CERTIFIED TO
ISO 9001:2008
CERT. NO: AR037

FIRE SUPPRESSION SYSTEM

Berdasarkan Piawaian
Complying with

NFPA 2001 & UL 2166

Syarikat Berdaftar
Registered company

VIC ENGINEERING SDN BHD (210158-P)
No. 2 & 4, Jalan Jenaris 2B,
Desa Sri Jenaris,
43000 Kajang,
Selangor Darul Ehsan.

Tempoh sah perakuan: **06/07/2017** hingga **05/07/2018**

(PKP)B HARON BIN HJ TAHIR
Bahagian Keselamatan Kebakaran,
b.p. Ketua Pengarah
Jabatan Bomba dan Penyelamat Malaysia.

Tarikh: 21 Jun 2017

** Peringatan:
Sila patuhi sepenuhnya syarat-syarat dan had kegunaan
seperti dalam Lampiran A1

No. Fail: JBPM/IP/BKK:700-7/2/22-104 (15)
No.Siri: AK/FSS/872/2011 (P6)

LAMPIRAN A1

Jenama	: 'HYGOOD SAPPHIRE'
Model & Spesifikasi	: NOVEC 1230 TOTAL FLOODING GAS SUPPRESSION SYSTEM
Nama & Alamat Pengeluar	: MACRON SAFETY SYSTEMS (UK) LIMITED
No. Laporan Ujian/Tarikh	: FM APPROVALS NO.3034075 (19/05/2009), UL EX4510 (27/01/2006) & UL GAQF.EX4510 (28/03/2016)
Skim Persijilan Barangan	: UL GAQF.EX5104 (08/02/2017)
Had Kegunaan	: DIBENARKAN UNTUK KAWASAN 'NORMALLY OCCUPIED AREA' DENGAN MEMATUHI NFPA 2001: EDITION 2008 DAN DISAHKAN OLEH KONSULTAN BERTAULIAH. MEMATUHI SYARAT-SYARAT SEPERTI DI LAMPIRAN A2 A3 & A4.



Tempoh sah perakuan: **06/07/2017 hingga 05/07/2018**