



CONTROL PANEL SCHEMATIC DIAGRAM

NOTE:
 NAC 1 - NAC INTERMITTENT CARD
 NAC 2 - ALARM 1
 NAC 3 - ALARM 2
 ZONE 1 - SMOKE
 ZONE 2 - HEAT
 EXTING - GAS DISCHARGE
 FIRE RELAY (C+NO) => MAIN FIRE ALARM PANEL

NO.	TARIKH	CATIHAN	DISEMAK



PENGEJUAL:
HYGOOD
 Unit 6, Enterprise Park
 Resopang Avenue, The Gardens,
 Manchester M17 1QS, United Kingdom.
 TEL : +44 (0)161 875 0402
 FXN : +44 (0)161 875 0491

PENGEJUAL SISTEM:
VIC ENGINEERING SDN. BHD. (Co. No. 210158-P)
 No. 2 & 4 Jalan Jenaris 2B, Desa Sri Jenaris,
 43000 Kajang, Selangor Darul Ehsan,
 MALAYSIA.
 E-Mail : genet@vic.com.my
 Website : <http://www.vic.com.my>
 TEL : (6) 03-8739 8043/8739 8690 (HL)
 FXN : (6) 03-8739 8043

COMPONENT INSTALLER:
TALUK PROJEK :

TALUK LUKISAN:
FIRE PROTECTION SYSTEMS
HYGOOD FM-200 SYSTEM
CONTROL PANEL SCHEMATIC DIAGRAM

UKURAN	TARIKH	DREKA
M1.3 (A1)	SEPT 2020	
DUNJUNG ASBIL	DESAK BRYAN	DILUKISAN ROBINSON LUI

NO. LUKISAN
 VIC - A1/CPSD/23920